

This document gives pertinent information concerning the reissuance of the VPDES Permit listed below. This permit is being processed as a minor, municipal permit. The discharge results from the operation of a 0.015 MGD wastewater treatment plant. The effluent limitations and special conditions contained in this permit will maintain the Water Quality Standards of 9 VAC 25-260-00 et seq.

1. Facility Name and Mailing Address: Notre Dame Academy WWTP
35321 Notre Dame Lane
Middleburg, VA 22117

Facility Location: 35321 Notre Dame Lane
Middleburg, VA 22117

Facility Contact Name: Cory Majtyka
Telephone Number: 540-687-5581

SIC Code: 4952 WWTP
County: Loudoun
2. Permit Number: VA0027197
Current Expiration Date: 22 April 2009

Other VPDES Permits: Not Applicable

Other Permits: PWSID 6107100

E2/E3/E4 Status: Not Applicable
3. Owner Name: Notre Dame Academy
Owner Contact/Title: Cory Majtyka
Maintenance Supervisor
Telephone Number: 540-687-5581
4. Application Complete Date: 21 October 2008
Permit Drafted By: Douglas Frasier
Date Drafted: 26 November 2008
Draft Permit Reviewed By: Alison Thompson
Date Reviewed: 4 December 2008
Public Comment Period: Start Date: 15 January 2009
End Date: 16 February 2009
5. Receiving Waters Information: See **Attachment 1** for the Flow Frequency Determination

Receiving Stream Name: Goose Creek, UT
Drainage Area at Outfall: 0.3 square miles
River Mile: 0.32
Stream Basin: Potomac River
Subbasin: Lower Potomac River
Section: 9
Stream Class: III
Special Standards: None
Waterbody ID: VAN-A05R
7Q10 Low Flow: 0.0 MGD
7Q10 High Flow: 0.0 MGD
1Q10 Low Flow: 0.0 MGD
1Q10 High Flow: 0.0 MGD
Harmonic Mean Flow: 0.0 MGD
30Q5 Flow: 0.0 MGD
303(d) Listed: No
30Q10 Flow: 0.0 MGD
TMDL Approved: Yes – Goose Creek
(bacteria/benthic)
Date TMDL Approved: 27 October 2007 – bacteria
(modification)
26 April 2004 – benthic
6. Statutory or Regulatory Basis for Special Conditions and Effluent Limitations:

<u>✓</u> State Water Control Law <u>✓</u> Clean Water Act <u>✓</u> VPDES Permit Regulation <u>✓</u> EPA NPDES Regulation	<u> </u> EPA Guidelines <u>✓</u> Water Quality Standards <u>✓</u> Other: Stream Model
---	--
7. Licensed Operator Requirements: Class IV
8. Reliability Class: Class II

9. Permit Characterization:

<input checked="" type="checkbox"/> Private	<input checked="" type="checkbox"/> Effluent Limited	<input type="checkbox"/> Possible Interstate Effect
<input type="checkbox"/> Federal	<input checked="" type="checkbox"/> Water Quality Limited	<input type="checkbox"/> Compliance Schedule Required
<input type="checkbox"/> State	<input type="checkbox"/> Toxics Monitoring Program Required	<input type="checkbox"/> Interim Limits in Permit
<input type="checkbox"/> POTW	<input type="checkbox"/> Pretreatment Program Required	<input type="checkbox"/> Interim Limits in Other Document
<input checked="" type="checkbox"/> TMDL		

10. Wastewater Sources and Treatment Description:

The Notre Dame Academy is a small private school with approximately 150 day students and seasonal school year residents. Therefore, the flow from this facility is considered continuous.

Sewage flows to the treatment plant via gravity through an 8-inch collection system that serves the school and its support facilities. Preliminary treatment consists of a comminutor and a bar screen; secondary treatment consists of an extended aeration unit with two blowers, air lift return sludge pumps, diffusers and a clarifier. Disinfection is accomplished through use of a tablet chlorinator and a baffled chlorine contact tank. Dechlorination is via tablet feeder.

Hydrated lime is manually added to the aeration basin for alkalinity adjustment. Effluent from the aeration basin flows to a clarifier equipped with an automatic skimmer. Manual skimming of the clarifier is also conducted routinely. After clarification, the effluent is chlorinated and dechlorinated prior to discharge. Accumulation of solids can occur in the chlorine contact tank. A pump has been installed to transfer these solids from the chlorine contact tank to the clarifier. Excess sludge is wasted to an aerobic/anaerobic digester. The supernatant from the digester discharges to the aeration basin.

After all sewage treatment, the effluent flows via gravity approximately 300 feet to Outfall 001. Discharge from Outfall 001 cascades down a rip-rap lined channel into an UT of Goose Creek. This process allows for some post-aeration. All sampling, except that needed to monitor the chlorine contact tank, is conducted at the outfall.

See **Attachment 2** for a facility schematic/diagram.

TABLE 1 OUTFALL DESCRIPTION				
Outfall Number	Discharge Sources	Treatment	Design Flow	Outfall Latitude and Longitude
001	Domestic Wastewater	See Item 10 above.	0.015 MGD	38° 59' 27.1" N 77° 47' 21.1" W
See Attachment 3 for the topographic map.				

11. Sludge Treatment and Disposal Methods:

Excess sludge is wasted to an aerobic/anaerobic digester that is cleaned approximately two to four times per year. Supernatant from the digester discharges to the aeration basin. Sludge from this facility is transported to the Blue Plans Interceptor near Leesburg.

The facility generates < 1 dry metric tons during a calendar year according to the permit application.

12. Discharges, Intakes, Monitoring Stations, Other Items in Vicinity of Discharge:

TABLE 2 DISCHARGES, INTAKES & MONITORING STATIONS		
ID / Permit Number	Description	Latitude / Longitude
1aGOO030.75	DEQ Ambient Monitoring Station	38° 59' 11" / 77° 47' 42"
VA0027197	Notre Dame Academy – minor municipal discharge	38° 59' 27" / 77° 47' 21"
VA0024112	Foxcroft School STP – minor municipal discharge	39° 00' 30" / 77° 45' 00"
1aGOO022.44	DEQ Ambient Monitoring Station	39° 00' 48" / 77° 42' 01"

13. Material Storage:

TABLE 3 MATERIAL STORAGE		
Materials Description	Volume Stored	Spill / Stormwater Prevention Measures
Hydrated Lime	One (1) 50 lb. bag	Under roof
Calcium Hypochlorite	One (1) 45 lb. container	
Sodium Sulfite	Three (3) 45 lb. container	Stored in buckets with lids adjacent to tablet feeder.

14. Site Inspection: Performed by NRO staff on 22 August 2008 (see **Attachment 4**).

15. Receiving Stream Water Quality and Water Quality Standards:a). Ambient Water Quality Data

The unnamed tributary to Goose Creek has not been monitored; thus, no ambient data is available. The nearest downstream monitoring station is 1aGOO0022.44, located on Goose Creek at the Snickersville Turnpike (Route 734) bridge crossing, approximately 8.3 rivermiles downstream from the confluence of the receiving stream and Goose Creek.

The following describes the water quality assessment results and listed impairments for the downstream waters of Goose Creek:

Recreational Use Impairment

Sufficient excursions from the instantaneous *E. coli* bacteria criterion and the single sample maximum fecal coliform bacteria criterion were recorded at DEQ ambient water quality monitoring stations.

Aquatic Life Use Impairment

Goose Creek is classified as slightly impaired; partially supporting due to a moderate benthic impairment.

Fish Consumption Impairment

The fish consumption use is categorized as impaired due to PCBs presence in fish tissue. The Virginia Department of Health has issued a fish consumption advisory.

The receiving stream was not included in the bacteria or benthic TMDL. However, both TMDLs did take into account all upstream point sources.

A fecal coliform TMDL for the Goose Creek watershed was developed and approved by the U.S. EPA on 1 May 2003 with a modification approval on 27 October 2006. The Wasteload Allocation, as listed in the TMDL Modification to the Goose Creek Watershed Bacteria TMDL, is 4.16×10^{10} cfu/year for Fecal Coliform and 2.62×10^{10} cfu/year for *E. coli* bacteria.

The benthic TMDL for the Goose Creek watershed was approved by the U.S. EPA on 26 April 2004. The facility was given a Wasteload Allocation for Total Suspended Solids (TSS) of 3.5 tons/year.

The TMDL to address the Fish Consumption impairments is scheduled to be completed in 2018.

b). Receiving Stream Water Quality Criteria

Part IX of 9 VAC 25-260(360-550) designates classes and special standards applicable to defined Virginia river basins and sections. The receiving stream, Goose Creek, UT, is located within Section 9 of the Potomac River Basin, and classified as Class III water.

At all times, Class III waters must achieve a dissolved oxygen (D.O.) of 4.0 mg/L or greater; a daily average D.O. of 5.0 mg/L or greater; a temperature that does not exceed 32°C; and maintain a pH of 6.0–9.0 standard units (S.U.).

Attachment 5 details other water quality criteria applicable to the receiving stream.

Ammonia:

Staff has re-evaluated the effluent data for pH and temperature and finds no significant difference from the data used to establish ammonia criteria and subsequent effluent limits in the previous permit. Therefore, the previously established pH and temperature values will be carried forward as part of this reissuance process.

Bacteria Criteria:

The Virginia Water Quality Standards (9 VAC 25-260-170.B.) states sewage discharges shall be disinfected to achieve the following criteria:

E. coli bacteria per 100 mL of water shall not exceed the following:

	Geometric Mean ¹	Single Sample Maximum
Freshwater <i>E. coli</i> (N/100 mL)	126	235

¹For two or more samples taken during any calendar month

c). Receiving Stream Special Standards

The State Water Control Board's Water Quality Standards, River Basin Section Tables (9 VAC 25-260-360, 370 and 380) designates the river basins, sections, classes and special standards for surface waters of the Commonwealth of Virginia. The receiving stream, Goose Creek, UT, is located within Section 9 of the Potomac River Basin. This section has not been designated with a special standard.

d). Threatened or Endangered Species

The Virginia DGIF Fish and Wildlife Information System Database was searched for records to determine if there are threatened or endangered species in the vicinity of the discharge. The following threatened or endangered species were identified within a 2 mile radius of the discharge: The Dwarf Wedgemussel, Wood Turtle, Upland Sandpiper (song bird), Henslow's Sparrow (song bird), Bald Eagle, Green Floater (mussel) and Migrant Loggerhead Shrike (song bird). The limits proposed in this draft permit are protective of the Virginia Water Quality Standards and therefore, protect the threatened and endangered species found near the discharge.

16. Antidegradation (9 VAC 25-260-30):

All state surface waters are provided one of three levels of antidegradation protection. For Tier 1 or existing use protection, existing uses of the water body and the water quality to protect these uses must be maintained. Tier 2 water bodies have water quality that is better than the water quality standards. Significant lowering of the water quality of Tier 2 waters is not allowed without an evaluation of the economic and social impacts. Tier 3 water bodies are exceptional waters and are so designated by regulatory amendment. The antidegradation policy prohibits new or expanded discharges into exceptional waters.

The receiving stream has been classified as Tier 1 based on the fact that the critical flows of the stream are 0.0 MGD. Permit limits proposed have been established by determining wasteload allocations which will result in attaining and/or maintaining all water quality criteria which apply to the receiving stream, including narrative criteria. These wasteload allocations will provide for the protection and maintenance of all existing uses.

17. Effluent Screening, Wasteload Allocation, and Effluent Limitation Development:

To determine water quality-based effluent limitations for a discharge, the suitability of data must first be determined. Data is suitable for analysis if one or more representative data points are equal to or above the quantification level ("QL") and the data represent the exact pollutant being evaluated.

Next, the appropriate Water Quality Standards (WQS) are determined for the pollutants in the effluent. Then, the Wasteload Allocations (WLA s) are calculated. In this case since the critical flows 7Q10 and 1Q10 have been determined to be zero, the WLAs are equal to the WQS. The WLA values are then compared with available effluent data to determine the need for effluent limitations. Effluent limitations are needed if the 97th percentile of the daily effluent concentration values is greater than the acute wasteload allocation or if the 97th percentile of the four-day average effluent concentration values is greater than the chronic wasteload allocation. Effluent limitations are based on the most limiting WLA, the required sampling frequency and statistical characteristics of the effluent data.

a). Effluent Screening

Effluent data obtained from Discharge Monitoring Reports (DMRs) has been reviewed and determined to be suitable for evaluation. A summary of the effluent data is located in the reissuance file.

b). Mixing Zones and Wasteload Allocations (WLAs)

Wasteload allocations (WLAs) are calculated for those parameters in the effluent with the reasonable potential to cause an exceedance of water quality criteria. The basic calculation for establishing a WLA is the steady state complete mix equation:

$$WLA = \frac{C_o [Q_e + (f) (Q_s)] - [(C_s) (f) (Q_s)]}{Q_e}$$

Where:	WLA	=	Wasteload allocation
	C _o	=	In-stream water quality criteria
	Q _e	=	Design flow
	Q _s	=	Critical receiving stream flow
		=	(1Q10 for acute aquatic life criteria; 7Q10 for chronic aquatic life criteria; harmonic mean for carcinogen-human health criteria; 30Q10 for ammonia criteria; and 30Q5 for non-carcinogen human health criteria)
	f	=	Decimal fraction of critical flow
	C _s	=	Mean background concentration of parameter in the receiving stream.

The water segment receiving the discharge via Outfall 001 is considered to have a 7Q10 and 1Q10 of 0.0 MGD; as such, there is no mixing zone and the WLA is equal to the C_o.

c). Effluent Limitations, Toxic Pollutants – Outfall 001

9 VAC 25-31-220.D. requires limits be imposed where a discharge has a reasonable potential to cause or contribute to an in-stream excursion of water quality criteria. Those parameters with WLAs that are near effluent concentrations are evaluated for limits.

The VPDES Permit Regulation at 9 VAC 25-31-230.D. requires that monthly and weekly average limitations be imposed for continuous discharges from POTWs and monthly average and daily maximum limitations be imposed for all other continuous non-POTW discharges.

(1) Ammonia as N:

Staff evaluated the new effluent data and has concluded it is not significantly different than what was used to derive the existing ammonia limits (**Attachment 6**). Therefore, existing ammonia limitations are proposed to continue in the reissued permit.

(2) Total Residual Chlorine:

Chlorine is used for disinfection and is potentially in the discharge. Staff calculated WLAs for TRC using current critical flows and the mixing allowance. In accordance with current DEQ guidance, staff used a default data point of 0.2 mg/L and the calculated WLAs to derive limits. A monthly average of 0.008 mg/L and a weekly average limit of 0.010 mg/L are proposed for this discharge (see **Attachment 7**).

d). Effluent Limitations and Monitoring, Outfall 001 – Conventional and Non-Conventional Pollutants

No changes to Dissolved Oxygen (D.O.), Biochemical Oxygen Demand-5 day (BOD₅), Total Suspended Solids (TSS), Ammonia and pH limitations are proposed.

Dissolved Oxygen limitations are based on the stream modeling conducted in June 1978 (**Attachment 8**) and are set to meet the water quality criteria for D.O. in the receiving stream.

The limitations for BOD₅ are based on Federal Secondary Treatment Standards, the 1978 stream model and the Virginia Water Quality Standards.

It is staff's practice to equate the Total Suspended Solids limits with the BOD₅ limitations since the two pollutants are closely related in terms of treatment of domestic sewage.

pH limitations are set at the water quality criteria.

E. coli limitations are in accordance with the Water Quality Standards 9 VAC 25-260-170.

e). Effluent Limitations and Monitoring Summary

The effluent limitations are presented in the following table. Limits were established for BOD₅, Total Suspended Solids, Ammonia, pH, Dissolved Oxygen, Total Residual Chlorine and *E. coli*.

The limit for Total Suspended Solids is based on Best Professional Judgement.

The mass loadings (kg/d), for monthly and weekly averages, were calculated by multiplying the concentration values (mg/L) with the flow values (in MGD) and a conversion factor of 3.785.

Sample Type and Frequency are in accordance with the recommendations in the VPDES Permit Manual.

18. Antibacksliding:

All limits in this permit are at least as stringent as those previously established. Backsliding does not apply to this reissuance.

19. Effluent Limitations/Monitoring Requirements:

Design flow is 0.015 MGD.

Effective Dates: During the period beginning with the permit's effective date and lasting until the expiration date.

PARAMETER	BASIS FOR LIMITS	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
		Monthly Average	Weekly Average	Minimum	Maximum	Frequency	Sample Type
Flow (MGD)	NA	NL	N/A	N/A	NL	1/D	EST
pH	3	N/A	N/A	6.0 S.U.	9.0 S.U.	1/D	Grab
BOD ₅	1,3,5	30 mg/L 1.7 kg/day	45 mg/L 2.6 kg/day	N/A	N/A	1/M	Grab
Total Suspended Solids (TSS)	1,2	30 mg/L 1.7 kg/day	45 mg/L 2.6 kg/day	N/A	N/A	1/M	Grab
DO	3,5	N/A	N/A	5.0 mg/L	N/A	1/D	Grab
Ammonia, as N	3	2.2 mg/L	2.2 mg/L	N/A	N/A	1/M	Grab
<i>E. coli</i>	3	N/A	N/A	N/A	235 n/100mL	1/M*	Grab
Total Residual Chlorine (after contact tank)	4	N/A	N/A	1.0 mg/L	N/A	1/D	Grab
Total Residual Chlorine (after dechlorination)	3	0.008 mg/L	0.010 mg/L	N/A	N/A	1/D	Grab

The basis for the limitations codes are:

- | | | |
|---------------------------------------|---|--------------------------------|
| 1. Federal Effluent Requirements | <i>MGD</i> = Million gallons per day. | <i>1/D</i> = Once every day. |
| 2. Best Professional Judgement | <i>N/A</i> = Not applicable. | <i>1/M</i> = Once every month. |
| 3. Water Quality Standards | <i>NL</i> = No limit; monitor and report. | |
| 4. DEQ Disinfection Guidance | <i>S.U.</i> = Standard units. | |
| 5. Stream Model – Attachment 8 | <i>TIRE</i> = Totalizing, indicating and recording equipment. | |

Estimate = Reported flow is to be based on the technical evaluation of the sources contributing to the discharge.

Grab = An individual sample collected over a period of time not to exceed 15-minutes.

* The permittee shall submit *E. coli* results for one year.If all sampling results for *E. coli* do not exceed 235 n/100mL, the permittee may submit a written request to DEQ-NRO for a reduction in the sampling frequency to once per quarter.

Upon approval, the permittee shall collect one sample within each quarterly monitoring period as defined below.

The quarterly monitoring periods shall be January through March; April through June; July through September; and October through December.

The DMR shall be submitted no later than the 10th day of the month following the monitoring period.

20. Other Permit Requirements:

Part I.B. of the permit contains additional chlorine monitoring requirements, quantification levels and compliance reporting instructions.

Minimum chlorine residual must be maintained at the exit of the chlorine contact tank to assure adequate disinfection. No more than three (3) of the monthly test results for TRC at the exit of the chlorine contact tank shall be < 1.0 mg/L with any TRC < 0.6 mg/L considered a system failure. *E. coli* limits are defined in this section as well as monitoring requirements to take effect should an alternate means of disinfection be used.

9 VAC 25-31-190.L.4.c. requires an arithmetic mean for measurement averaging and 9 VAC 25-31-220.D. requires limits be imposed where a discharge has a reasonable potential to cause or contribute to an in-stream excursion of water quality criteria. Specific analytical methodologies for toxics are listed in this permit section as well as quantification levels (QLs) necessary to demonstrate compliance with applicable permit limitations or for use in future evaluations to determine if the pollutant has reasonable potential to cause or contribute to a violation. Required averaging methodologies are also specified.

21. Other Special Conditions:

- a) 95% Capacity Reopener. The VPDES Permit Regulation at 9 VAC 25-31-200.B.2. requires all POTWs and PVOTWs develop and submit a plan of action to DEQ when the monthly average influent flow to their sewage treatment plant reaches 95% or more of the design capacity authorized in the permit for each month of any three consecutive month period. The facility is a PVOTW.
- b) Indirect Dischargers. Required by VPDES Permit Regulation, 9 VAC 25-31-280 B.9 for POTWs and PVOTWs that receive waste from someone other than the owner of the treatment works.
- c) O&M Manual Requirement. Required by Code of Virginia §62.1-44.19; Sewage Collection and Treatment Regulations, 9 VAC 25-790; VPDES Permit Regulation, 9 VAC 25-31-190.E. Before or on 22 July 2009, the permittee shall submit for approval an Operations and Maintenance (O&M) Manual or a statement confirming the accuracy and completeness of the current O&M Manual to the Department of Environmental Quality, Northern Regional Office (DEQ-NRO). Future changes to the facility must be addressed by the submittal of a revised O&M Manual within 90 days of the changes. Non-compliance with the O&M Manual shall be deemed a violation of the permit.
- d) CTC, CTO Requirement. The Code of Virginia § 62.1-44.19; Sewage Collection and Treatment Regulations, 9 VAC 25-790 requires that all treatment works treating wastewater obtain a Certificate to Construct prior to commencing construction and to obtain a Certificate to Operate prior to commencing operation of the treatment works.
- e) Licensed Operator Requirement. The Code of Virginia at §54.1-2300 et seq. and the VPDES Permit Regulation at 9 VAC 25-31-200 D, and Rules and Regulations for Waterworks and Wastewater Works Operators (18 VAC 160-20-10 et seq.) requires licensure of operators. This facility requires a Class IV operator.
- f) Reliability Class. The Sewage Collection and Treatment Regulation at 9 VAC 25-790 requires sewerage works achieve a certain level of reliability in order to protect water quality and public health consequences in the event of component or system failure. The facility is required to meet reliability Class II.
- g) Sludge Reopener. The VPDES Permit Regulation at 9 VAC 25-31-200.C.4. requires all permits issued to treatment works treating domestic sewage (including sludge-only facilities) include a reopener clause allowing incorporation of any applicable standard for sewage sludge use or disposal promulgated under Section 405(d) of the CWA. The facility includes a sewage treatment works.
- h) Sludge Use and Disposal. The VPDES Permit Regulation at 9 VAC 25-31-100.P., 220.B.2., and 420-720, and 40 CFR Part 503 require all treatment works treating domestic sewage to submit information on their sludge use and disposal practices and to meet specified standards for sludge use and disposal. The facility includes a treatment works treating domestic sewage.

- 22. Permit Section Part II:** Part II of the permit contains standard conditions that appear in all VPDES Permits. In general, these standard conditions address the responsibilities of the permittee, reporting requirements, testing procedures and records retention.

23. Changes to the Permit from the Previously Issued Permit:

- a) Special Conditions:
 - CTC, CTO Requirement condition included with this reissuance.
 - Chlorine demonstration was removed.
- b) Monitoring and Effluent Limitations:
 - *E. coli* sampling was included with this reissuance to reflect current agency guidance.

- 24. Variances/Alternate Limits or Conditions:** The permittee may request that the *E. coli* sampling frequency be reduced to once per calendar quarter based on results obtained during the first year of this permit term.

25. Public Notice Information:

First Public Notice Date: 14 January 2009

Second Public Notice Date: 21 January 2009

Public Notice Information is required by 9 VAC 25-31-280.B. All pertinent information is on file and may be inspected and copied by contacting the: DEQ Northern Regional Office, 13901 Crown Court, Woodbridge, VA 22193, Telephone No. (703) 583-3873, ddfrasier@deq.virginia.gov. See **Attachment 9** for a copy of the public notice document.

Persons may comment in writing or by email to the DEQ on the proposed permit action, and may request a public hearing, during the comment period. Comments shall include the name, address, and telephone number of the writer and shall contain a complete, concise statement of the factual basis for comments. Only those comments received within this period will be considered. The DEQ may decide to hold a public hearing if public response is significant. Requests for public hearings shall state the reason why a hearing is requested, the nature of the issues proposed to be raised in the public hearing and a brief explanation of how the requester's interests would be directly and adversely affected by the proposed permit action. Following the comment period, the Board will make a determination regarding the proposed permit action. This determination will become effective, unless the DEQ grants a public hearing. Due notice of any public hearing will be given.

26. 303 (d) Listed Stream Segments and Total Max. Daily Loads (TMDL):

A fecal coliform TMDL for the Goose Creek watershed was developed and approved by the U.S. EPA on 1 May 2003 with a modification approval on 27 October 2006. The Wasteload Allocation, as listed in the TMDL Modification to the Goose Creek Watershed Bacteria TMDL, is 4.16×10^{10} cfu/year for Fecal Coliform and 2.62×10^{10} cfu/year for *E. coli* bacteria.

The benthic TMDL for Goose Creek did not specifically include Sycolin Creek; however, it did take into account all upstream point sources. A benthic TMDL for the Goose Creek watershed was approved by the U.S. EPA on 26 April 2004. The facility was given a Wasteload Allocation for Total Suspended Solids (TSS) of 3.5 /year.

The proposed bacteria and TSS limitations should not contribute to the further impairment of water quality.

TMDL Reopener: This special condition is to allow the permit to be reopened if necessary to bring it into compliance with any applicable TMDL that may be developed and approved for the receiving stream.

27. Additional Comments:

Previous Board Action(s): None.

Staff Comments: None.

Public Comment: No comments were received during the public notice

EPA Checklist: The checklist can be found in **Attachment 10**.

Fact Sheet Attachments

Table of Contents

Notre Dame Academy
VA0027197
2009 Reissuance

Attachment 1	Flow Frequency Determination
Attachment 2	Facility Schematic/Diagram
Attachment 3	Topographic Map
Attachment 4	Inspection Summary Report
Attachment 5	Wasteload Allocation Analyses
Attachment 6	Ammonia Limitation Derivation
Attachment 7	Total Residual Chlorine Limitation Derivation
Attachment 8	June 1978 Stream Model
Attachment 9	Public Notice
Attachment 10	EPA Checklist

MEMORANDUM

DEPARTMENT OF ENVIRONMENTAL QUALITY - WATER DIVISION
Water Quality Assessments and Planning
629 E. Main Street P.O. Box 10009 Richmond, Virginia 23240

SUBJECT: Flow Frequency Determination
Notre Dame Academy STP - VA#0027197

TO: Doug Stockman, NRO

FROM: Paul E. Herman, P.E., WQAP

DATE: August 14, 1998

COPIES: Ron Gregory, Charles Martin, File

Northern VA. Region
Dept. of Env. Quality

RECEIVED
AUG 18 1998

This memo supercedes my September 10, 1993 memo to Joan Crowther concerning the subject VPDES permit.

The Notre Dame Academy STP discharges to an unnamed tributary of the Goose Creek near Middleburg, VA. Stream flow frequencies are required at this site for use by the permit writer in developing effluent limitations for the VPDES permit.

The values at the discharge point were determined by inspection of the USGS Rectortown Quadrangle topographical map which shows the receiving stream as intermittent at the discharge point. The flow frequencies for intermittent streams are 0.0 cfs for the 1Q10, 7Q10, 30Q5, high flow 1Q10, high flow 7Q10, and the harmonic mean. Flow frequencies have been provided for the first perennial point downstream of the outfall. This occurs on the Goose Creek above its confluence with the intermittent stream.

The VDEQ operated a continuous record gage on the Goose Creek near Middleburg, VA (#01643700) from 1965 to 1967 and from 1969 through 1996. The gage was located approximately 1000 feet upstream of the intermittent discharge receiving stream. The flow frequencies for the gage and the perennial point are presented below. The values at the perennial point are considered equal to those at the gage due to the close proximity of one to the other.


Goose Creek near Middleburg, VA (#01643700)
and at perennial point:

Drainage Area = 123 mi ²		
1Q10 = 0.0	cfs	High Flow 1Q10 = 8.6 cfs
7Q10 = 0.0037	cfs	High Flow 7Q10 = 11 cfs
30Q5 = 1.55	cfs	HM = 0.0 cfs


The high flow months are December through May. If you have any questions concerning this analysis, please let me know.

2

6/98
(NTS)



Notre Dame Academy
Wastewater Treatment Facility
Sludge Handling System



Problems identified at last inspection, March 24, 2004:

	Corrected	Not Corrected
1. Recommend that the facility ascertain the possible source(s) of the solids problem and provide, in writing, corrective measures to be employed to reduce Remedy the solids dilemma by May 28, 2004.	[X]	[]
3. The O&M Manual should be updated to reflect the solids issue, the possible sources discovered, and corrective actions taken.	[X]	[]

Technical Inspection Summary, August 22, 2008**Comments:**

- The aeration basin and clarifier have been covered with grating to prevent leaves and debris from falling into the tanks.
- This facility has a history of documented solids loss through the outfall into the receiving stream (March 2004, March 2006).
- This facility also has had problems with violating the permit's ammonia-n limits, generally in the colder months of the year. Solids in the CCT have been given as part of the reason for these violations.

Recommendations for action:

- Several sections in the O&M Manual need to be updated as a result of changes in the plant operations, including the Immersion heaters added to the aeration basin, a baffle added to contain solids in aeration basin, and the DR100 is no longer used for Total Residual Chlorine analysis. An updated O&M will be required when the permit is reissued early next year.

FRESHWATER WATER QUALITY CRITERIA / WASTELOAD ALLOCATION ANALYSIS

Facility Name: **Notre Dame Academy STP**

Permit No.: **VA0027197**

Receiving Stream: **Goose Creek, UT**

Version: OWP Guidance Memo 00-2011 (8/24/00)

Stream Information

Mean Hardness (as CaCO3) =	mg/L
90% Temperature (Annual) =	deg C
90% Temperature (Wet season) =	deg C
90% Maximum pH =	SU
10% Maximum pH =	SU
Tier Designation (1 or 2) =	1
Public Water Supply (PWS) Y/N? =	n
Trout Present Y/N? =	n
Early Life Stages Present Y/N? =	y

Stream Flows

1Q10 (Annual) =	0 MGD
7Q10 (Annual) =	0 MGD
30Q10 (Annual) =	0 MGD
1Q10 (Wet season) =	0 MGD
30Q10 (Wet season) =	0 MGD
30Q5 =	0 MGD
Harmonic Mean =	0 MGD
Annual Average =	0 MGD

Mixing Information

Annual - 1Q10 Mix =	0 %
- 7Q10 Mix =	0 %
- 30Q10 Mix =	0 %
Wet Season - 1Q10 Mix =	0 %
- 30Q10 Mix =	0 %

Effluent Information

Mean Hardness (as CaCO3) =	50 mg/L
90% Temp (Annual) =	25 deg C
90% Temp (Wet season) =	deg C
90% Maximum pH =	7.5 SU
10% Maximum pH =	SU
Discharge Flow =	0.015 MGD

Parameter (ug/l unless noted)	Background Conc.	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				Most Limiting Allocations			
		Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH
Acenapthene	0	--	--	na	2.7E+03	--	--	na	2.7E+03	--	--	--	--	--	--	--	--	--	--	na	2.7E+03
Acrolein	0	--	--	na	7.8E+02	--	--	na	7.8E+02	--	--	--	--	--	--	--	--	--	--	na	7.8E+02
Acrylonitrile ^C	0	--	--	na	6.6E+00	--	--	na	6.6E+00	--	--	--	--	--	--	--	--	--	--	na	6.6E+00
Aldrin ^C	0	3.0E+00	--	na	1.4E-03	3.0E+00	--	na	1.4E-03	--	--	--	--	--	--	--	--	3.0E+00	--	na	1.4E-03
Ammonia-N (mg/l) (Yearly)	0	1.99E+01	2.22E+00	na	--	2.0E+01	2.2E+00	na	--	--	--	--	--	--	--	--	--	2.0E+01	2.2E+00	na	--
Ammonia-N (mg/l) (High Flow)	0	1.99E+01	4.36E+00	na	--	2.0E+01	4.4E+00	na	--	--	--	--	--	--	--	--	--	2.0E+01	4.4E+00	na	--
Anthracene	0	--	--	na	1.1E+05	--	--	na	1.1E+05	--	--	--	--	--	--	--	--	--	--	na	1.1E+05
Antimony	0	--	--	na	4.3E+03	--	--	na	4.3E+03	--	--	--	--	--	--	--	--	--	--	na	4.3E+03
Arsenic	0	3.4E+02	1.5E+02	na	--	3.4E+02	1.5E+02	na	--	--	--	--	--	--	--	--	--	3.4E+02	1.5E+02	na	--
Barium	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
Benzene ^C	0	--	--	na	7.1E+02	--	--	na	7.1E+02	--	--	--	--	--	--	--	--	--	--	na	7.1E+02
Benzidine ^C	0	--	--	na	5.4E-03	--	--	na	5.4E-03	--	--	--	--	--	--	--	--	--	--	na	5.4E-03
Benzo (a) anthracene ^C	0	--	--	na	4.9E-01	--	--	na	4.9E-01	--	--	--	--	--	--	--	--	--	--	na	4.9E-01
Benzo (b) fluoranthene ^C	0	--	--	na	4.9E-01	--	--	na	4.9E-01	--	--	--	--	--	--	--	--	--	--	na	4.9E-01
Benzo (k) fluoranthene ^C	0	--	--	na	4.9E-01	--	--	na	4.9E-01	--	--	--	--	--	--	--	--	--	--	na	4.9E-01
Benzo (a) pyrene ^C	0	--	--	na	4.9E-01	--	--	na	4.9E-01	--	--	--	--	--	--	--	--	--	--	na	4.9E-01
Bis2-Chloroethyl Ether	0	--	--	na	1.4E+01	--	--	na	1.4E+01	--	--	--	--	--	--	--	--	--	--	na	1.4E+01
Bis2-Chloroisopropyl Ether	0	--	--	na	1.7E+05	--	--	na	1.7E+05	--	--	--	--	--	--	--	--	--	--	na	1.7E+05
Bromoform ^C	0	--	--	na	3.6E+03	--	--	na	3.6E+03	--	--	--	--	--	--	--	--	--	--	na	3.6E+03
Butylbenzylphthalate	0	--	--	na	5.2E+03	--	--	na	5.2E+03	--	--	--	--	--	--	--	--	--	--	na	5.2E+03
Cadmium	0	1.8E+00	6.6E-01	na	--	1.8E+00	6.6E-01	na	--	--	--	--	--	--	--	--	--	1.8E+00	6.6E-01	na	--
Carbon Tetrachloride ^C	0	--	--	na	4.4E+01	--	--	na	4.4E+01	--	--	--	--	--	--	--	--	--	--	na	4.4E+01
Chlordane ^C	0	2.4E+00	4.3E-03	na	2.2E-02	2.4E+00	4.3E-03	na	2.2E-02	--	--	--	--	--	--	--	--	2.4E+00	4.3E-03	na	2.2E-02
Chloride	0	8.6E+05	2.3E+05	na	--	8.6E+05	2.3E+05	na	--	--	--	--	--	--	--	--	--	8.6E+05	2.3E+05	na	--
TRC	0	1.9E+01	1.1E+01	na	--	1.9E+01	1.1E+01	na	--	--	--	--	--	--	--	--	--	1.9E+01	1.1E+01	na	--
Chlorobenzene	0	--	--	na	2.1E+04	--	--	na	2.1E+04	--	--	--	--	--	--	--	--	--	--	na	2.1E+04

Parameter (ug/l unless noted)	Background Conc.	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				Most Limiting Allocations			
		Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH
Chlorodibromomethane ^C	0	--	--	na	3.4E+02	--	--	na	3.4E+02	--	--	--	--	--	--	--	--	--	--	na	3.4E+02
Chloroform ^C	0	--	--	na	2.9E+04	--	--	na	2.9E+04	--	--	--	--	--	--	--	--	--	--	na	2.9E+04
2-Chloronaphthalene	0	--	--	na	4.3E+03	--	--	na	4.3E+03	--	--	--	--	--	--	--	--	--	--	na	4.3E+03
2-Chlorophenol	0	--	--	na	4.0E+02	--	--	na	4.0E+02	--	--	--	--	--	--	--	--	--	--	na	4.0E+02
Chlorpyrifos	0	8.3E-02	4.1E-02	na	--	8.3E-02	4.1E-02	na	--	--	--	--	--	--	--	--	--	8.3E-02	4.1E-02	na	--
Chromium III	0	3.2E+02	4.2E+01	na	--	3.2E+02	4.2E+01	na	--	--	--	--	--	--	--	--	--	3.2E+02	4.2E+01	na	--
Chromium VI	0	1.6E+01	1.1E+01	na	--	1.6E+01	1.1E+01	na	--	--	--	--	--	--	--	--	--	1.6E+01	1.1E+01	na	--
Chromium, Total	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
Chrysene ^C	0	--	--	na	4.9E-01	--	--	na	4.9E-01	--	--	--	--	--	--	--	--	--	--	na	4.9E-01
Copper	0	7.0E+00	5.0E+00	na	--	7.0E+00	5.0E+00	na	--	--	--	--	--	--	--	--	--	7.0E+00	5.0E+00	na	--
Cyanide	0	2.2E+01	5.2E+00	na	2.2E+05	2.2E+01	5.2E+00	na	2.2E+05	--	--	--	--	--	--	--	--	2.2E+01	5.2E+00	na	2.2E+05
DDD ^C	0	--	--	na	8.4E-03	--	--	na	8.4E-03	--	--	--	--	--	--	--	--	--	--	na	8.4E-03
DDE ^C	0	--	--	na	5.9E-03	--	--	na	5.9E-03	--	--	--	--	--	--	--	--	--	--	na	5.9E-03
DDT ^C	0	1.1E+00	1.0E-03	na	5.9E-03	1.1E+00	1.0E-03	na	5.9E-03	--	--	--	--	--	--	--	--	1.1E+00	1.0E-03	na	5.9E-03
Demeton	0	--	1.0E-01	na	--	--	1.0E-01	na	--	--	--	--	--	--	--	--	--	--	1.0E-01	na	--
Dibenz(a,h)anthracene ^C	0	--	--	na	4.9E-01	--	--	na	4.9E-01	--	--	--	--	--	--	--	--	--	--	na	4.9E-01
Dibutyl phthalate	0	--	--	na	1.2E+04	--	--	na	1.2E+04	--	--	--	--	--	--	--	--	--	--	na	1.2E+04
Dichloromethane (Methylene Chloride) ^C	0	--	--	na	1.6E+04	--	--	na	1.6E+04	--	--	--	--	--	--	--	--	--	--	na	1.6E+04
1,2-Dichlorobenzene	0	--	--	na	1.7E+04	--	--	na	1.7E+04	--	--	--	--	--	--	--	--	--	--	na	1.7E+04
1,3-Dichlorobenzene	0	--	--	na	2.6E+03	--	--	na	2.6E+03	--	--	--	--	--	--	--	--	--	--	na	2.6E+03
1,4-Dichlorobenzene	0	--	--	na	2.6E+03	--	--	na	2.6E+03	--	--	--	--	--	--	--	--	--	--	na	2.6E+03
3,3-Dichlorobenzidine ^C	0	--	--	na	7.7E-01	--	--	na	7.7E-01	--	--	--	--	--	--	--	--	--	--	na	7.7E-01
Dichlorobromomethane ^C	0	--	--	na	4.6E+02	--	--	na	4.6E+02	--	--	--	--	--	--	--	--	--	--	na	4.6E+02
1,2-Dichloroethane ^C	0	--	--	na	9.9E+02	--	--	na	9.9E+02	--	--	--	--	--	--	--	--	--	--	na	9.9E+02
1,1-Dichloroethylene	0	--	--	na	1.7E+04	--	--	na	1.7E+04	--	--	--	--	--	--	--	--	--	--	na	1.7E+04
1,2-trans-dichloroethylene	0	--	--	na	1.4E+05	--	--	na	1.4E+05	--	--	--	--	--	--	--	--	--	--	na	1.4E+05
2,4-Dichlorophenol	0	--	--	na	7.9E+02	--	--	na	7.9E+02	--	--	--	--	--	--	--	--	--	--	na	7.9E+02
2,4-Dichlorophenoxy acetic acid (2,4-D)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
1,2-Dichloropropane ^C	0	--	--	na	3.9E+02	--	--	na	3.9E+02	--	--	--	--	--	--	--	--	--	--	na	3.9E+02
1,3-Dichloropropene	0	--	--	na	1.7E+03	--	--	na	1.7E+03	--	--	--	--	--	--	--	--	--	--	na	1.7E+03
Dieldrin ^C	0	2.4E-01	5.6E-02	na	1.4E-03	2.4E-01	5.6E-02	na	1.4E-03	--	--	--	--	--	--	--	--	2.4E-01	5.6E-02	na	1.4E-03
Diethyl Phthalate	0	--	--	na	1.2E+05	--	--	na	1.2E+05	--	--	--	--	--	--	--	--	--	--	na	1.2E+05
Di-2-Ethylhexyl Phthalate ^C	0	--	--	na	5.9E+01	--	--	na	5.9E+01	--	--	--	--	--	--	--	--	--	--	na	5.9E+01
2,4-Dimethylphenol	0	--	--	na	2.3E+03	--	--	na	2.3E+03	--	--	--	--	--	--	--	--	--	--	na	2.3E+03
Dimethyl Phthalate	0	--	--	na	2.9E+06	--	--	na	2.9E+06	--	--	--	--	--	--	--	--	--	--	na	2.9E+06
Di-n-Butyl Phthalate	0	--	--	na	1.2E+04	--	--	na	1.2E+04	--	--	--	--	--	--	--	--	--	--	na	1.2E+04
2,4 Dinitrophenol	0	--	--	na	1.4E+04	--	--	na	1.4E+04	--	--	--	--	--	--	--	--	--	--	na	1.4E+04
2-Methyl-4,6-Dinitrophenol	0	--	--	na	7.65E+02	--	--	na	7.7E+02	--	--	--	--	--	--	--	--	--	--	na	7.7E+02
2,4-Dinitrotoluene ^C	0	--	--	na	9.1E+01	--	--	na	9.1E+01	--	--	--	--	--	--	--	--	--	--	na	9.1E+01
Dioxin (2,3,7,8- tetrachlorodibenzo-p- dioxin) (ppq)	0	--	--	na	1.2E-06	--	--	na	na	--	--	--	--	--	--	--	--	--	--	na	na
1,2-Diphenylhydrazine ^C	0	--	--	na	5.4E+00	--	--	na	5.4E+00	--	--	--	--	--	--	--	--	--	--	na	5.4E+00
Alpha-Endosulfan	0	2.2E-01	5.6E-02	na	2.4E+02	2.2E-01	5.6E-02	na	2.4E+02	--	--	--	--	--	--	--	--	2.2E-01	5.6E-02	na	2.4E+02
Beta-Endosulfan	0	2.2E-01	5.6E-02	na	2.4E+02	2.2E-01	5.6E-02	na	2.4E+02	--	--	--	--	--	--	--	--	2.2E-01	5.6E-02	na	2.4E+02
Endosulfan Sulfate	0	--	--	na	2.4E+02	--	--	na	2.4E+02	--	--	--	--	--	--	--	--	--	--	na	2.4E+02
Endrin	0	8.6E-02	3.6E-02	na	8.1E-01	8.6E-02	3.6E-02	na	8.1E-01	--	--	--	--	--	--	--	--	8.6E-02	3.6E-02	na	8.1E-01
Endrin Aldehyde	0	--	--	na	8.1E-01	--	--	na	8.1E-01	--	--	--	--	--	--	--	--	--	--	na	8.1E-01

Parameter (ug/l unless noted)	Background Conc.	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				Most Limiting Allocations			
		Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH
Ethylbenzene	0	--	--	na	2.9E+04	--	--	na	2.9E+04	--	--	--	--	--	--	--	--	--	--	na	2.9E+04
Fluoranthene	0	--	--	na	3.7E+02	--	--	na	3.7E+02	--	--	--	--	--	--	--	--	--	--	na	3.7E+02
Fluorene	0	--	--	na	1.4E+04	--	--	na	1.4E+04	--	--	--	--	--	--	--	--	--	--	na	1.4E+04
Foaming Agents	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
Guthion	0	--	1.0E-02	na	--	--	1.0E-02	na	--	--	--	--	--	--	--	--	--	--	1.0E-02	na	--
Heptachlor ^C	0	5.2E-01	3.8E-03	na	2.1E-03	5.2E-01	3.8E-03	na	2.1E-03	--	--	--	--	--	--	--	--	5.2E-01	3.8E-03	na	2.1E-03
Heptachlor Epoxide ^C	0	5.2E-01	3.8E-03	na	1.1E-03	5.2E-01	3.8E-03	na	1.1E-03	--	--	--	--	--	--	--	--	5.2E-01	3.8E-03	na	1.1E-03
Hexachlorobenzene ^C	0	--	--	na	7.7E-03	--	--	na	7.7E-03	--	--	--	--	--	--	--	--	--	--	na	7.7E-03
Hexachlorobutadiene ^C	0	--	--	na	5.0E+02	--	--	na	5.0E+02	--	--	--	--	--	--	--	--	--	--	na	5.0E+02
Hexachlorocyclohexane																					
Alpha-BHC ^C	0	--	--	na	1.3E-01	--	--	na	1.3E-01	--	--	--	--	--	--	--	--	--	--	na	1.3E-01
Hexachlorocyclohexane																					
Beta-BHC ^C	0	--	--	na	4.6E-01	--	--	na	4.6E-01	--	--	--	--	--	--	--	--	--	--	na	4.6E-01
Hexachlorocyclohexane																					
Gamma-BHC ^C (Lindane)	0	9.5E-01	na	na	6.3E-01	9.5E-01	--	na	6.3E-01	--	--	--	--	--	--	--	--	9.5E-01	--	na	6.3E-01
Hexachlorocyclopentadiene	0	--	--	na	1.7E+04	--	--	na	1.7E+04	--	--	--	--	--	--	--	--	--	--	na	1.7E+04
Hexachloroethane ^C	0	--	--	na	8.9E+01	--	--	na	8.9E+01	--	--	--	--	--	--	--	--	--	--	na	8.9E+01
Hydrogen Sulfide	0	--	2.0E+00	na	--	--	2.0E+00	na	--	--	--	--	--	--	--	--	--	--	2.0E+00	na	--
Indeno (1,2,3-cd) pyrene ^C	0	--	--	na	4.9E-01	--	--	na	4.9E-01	--	--	--	--	--	--	--	--	--	--	na	4.9E-01
Iron	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
Isophorone ^C	0	--	--	na	2.6E+04	--	--	na	2.6E+04	--	--	--	--	--	--	--	--	--	--	na	2.6E+04
Kepone	0	--	0.0E+00	na	--	--	0.0E+00	na	--	--	--	--	--	--	--	--	--	--	0.0E+00	na	--
Lead	0	4.9E+01	5.6E+00	na	--	4.9E+01	5.6E+00	na	--	--	--	--	--	--	--	--	--	4.9E+01	5.6E+00	na	--
Malathion	0	--	1.0E-01	na	--	--	1.0E-01	na	--	--	--	--	--	--	--	--	--	--	1.0E-01	na	--
Manganese	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
Mercury	0	1.4E+00	7.7E-01	na	5.1E-02	1.4E+00	7.7E-01	na	5.1E-02	--	--	--	--	--	--	--	--	1.4E+00	7.7E-01	na	5.1E-02
Methyl Bromide	0	--	--	na	4.0E+03	--	--	na	4.0E+03	--	--	--	--	--	--	--	--	--	--	na	4.0E+03
Methoxychlor	0	--	3.0E-02	na	--	--	3.0E-02	na	--	--	--	--	--	--	--	--	--	--	3.0E-02	na	--
Mirex	0	--	0.0E+00	na	--	--	0.0E+00	na	--	--	--	--	--	--	--	--	--	--	0.0E+00	na	--
Monochlorobenzene	0	--	--	na	2.1E+04	--	--	na	2.1E+04	--	--	--	--	--	--	--	--	--	--	na	2.1E+04
Nickel	0	1.0E+02	1.1E+01	na	4.6E+03	1.0E+02	1.1E+01	na	4.6E+03	--	--	--	--	--	--	--	--	1.0E+02	1.1E+01	na	4.6E+03
Nitrate (as N)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
Nitrobenzene	0	--	--	na	1.9E+03	--	--	na	1.9E+03	--	--	--	--	--	--	--	--	--	--	na	1.9E+03
N-Nitrosodimethylamine ^C	0	--	--	na	8.1E+01	--	--	na	8.1E+01	--	--	--	--	--	--	--	--	--	--	na	8.1E+01
N-Nitrosodiphenylamine ^C	0	--	--	na	1.6E+02	--	--	na	1.6E+02	--	--	--	--	--	--	--	--	--	--	na	1.6E+02
N-Nitrosodi-n-propylamine ^C	0	--	--	na	1.4E+01	--	--	na	1.4E+01	--	--	--	--	--	--	--	--	--	--	na	1.4E+01
Parathion	0	6.5E-02	1.3E-02	na	--	6.5E-02	1.3E-02	na	--	--	--	--	--	--	--	--	--	6.5E-02	1.3E-02	na	--
PCB-1016	0	--	1.4E-02	na	--	--	1.4E-02	na	--	--	--	--	--	--	--	--	--	--	1.4E-02	na	--
PCB-1221	0	--	1.4E-02	na	--	--	1.4E-02	na	--	--	--	--	--	--	--	--	--	--	1.4E-02	na	--
PCB-1232	0	--	1.4E-02	na	--	--	1.4E-02	na	--	--	--	--	--	--	--	--	--	--	1.4E-02	na	--
PCB-1242	0	--	1.4E-02	na	--	--	1.4E-02	na	--	--	--	--	--	--	--	--	--	--	1.4E-02	na	--
PCB-1248	0	--	1.4E-02	na	--	--	1.4E-02	na	--	--	--	--	--	--	--	--	--	--	1.4E-02	na	--
PCB-1254	0	--	1.4E-02	na	--	--	1.4E-02	na	--	--	--	--	--	--	--	--	--	--	1.4E-02	na	--
PCB-1260	0	--	1.4E-02	na	--	--	1.4E-02	na	--	--	--	--	--	--	--	--	--	--	1.4E-02	na	--
PCB Total ^C	0	--	--	na	1.7E-03	--	--	na	1.7E-03	--	--	--	--	--	--	--	--	--	--	na	1.7E-03

Parameter (ug/l unless noted)	Background Conc.	Water Quality Criteria				Wasteload Allocations				Antidegradation Baseline				Antidegradation Allocations				Most Limiting Allocations			
		Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH	Acute	Chronic	HH (PWS)	HH
Pentachlorophenol ^C	0	7.7E-03	5.9E-03	na	8.2E+01	7.7E-03	5.9E-03	na	8.2E+01	--	--	--	--	--	--	--	--	7.7E-03	5.9E-03	na	8.2E+01
Phenol	0	--	--	na	4.6E+06	--	--	na	4.6E+06	--	--	--	--	--	--	--	--	--	--	na	4.6E+06
Pyrene	0	--	--	na	1.1E+04	--	--	na	1.1E+04	--	--	--	--	--	--	--	--	--	--	na	1.1E+04
Radionuclides (pCi/l except Beta/Photon)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
Gross Alpha Activity	0	--	--	na	1.5E+01	--	--	na	1.5E+01	--	--	--	--	--	--	--	--	--	--	na	1.5E+01
Beta and Photon Activity (mrem/yr)	0	--	--	na	4.0E+00	--	--	na	4.0E+00	--	--	--	--	--	--	--	--	--	--	na	4.0E+00
Strontium-90	0	--	--	na	8.0E+00	--	--	na	8.0E+00	--	--	--	--	--	--	--	--	--	--	na	8.0E+00
Tritium	0	--	--	na	2.0E+04	--	--	na	2.0E+04	--	--	--	--	--	--	--	--	--	--	na	2.0E+04
Selenium	0	2.0E+01	5.0E+00	na	1.1E+04	2.0E+01	5.0E+00	na	1.1E+04	--	--	--	--	--	--	--	--	2.0E+01	5.0E+00	na	1.1E+04
Silver	0	1.0E+00	--	na	--	1.0E+00	--	na	--	--	--	--	--	--	--	--	--	1.0E+00	--	na	--
Sulfate	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
1,1,2,2-Tetrachloroethane ^C	0	--	--	na	1.1E+02	--	--	na	1.1E+02	--	--	--	--	--	--	--	--	--	--	na	1.1E+02
Tetrachloroethylene ^C	0	--	--	na	8.9E+01	--	--	na	8.9E+01	--	--	--	--	--	--	--	--	--	--	na	8.9E+01
Thallium	0	--	--	na	6.3E+00	--	--	na	6.3E+00	--	--	--	--	--	--	--	--	--	--	na	6.3E+00
Toluene	0	--	--	na	2.0E+05	--	--	na	2.0E+05	--	--	--	--	--	--	--	--	--	--	na	2.0E+05
Total dissolved solids	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
Toxaphene ^C	0	7.3E-01	2.0E-04	na	7.5E-03	7.3E-01	2.0E-04	na	7.5E-03	--	--	--	--	--	--	--	--	7.3E-01	2.0E-04	na	7.5E-03
Tributyltin	0	4.6E-01	6.3E-02	na	--	4.6E-01	6.3E-02	na	--	--	--	--	--	--	--	--	--	4.6E-01	6.3E-02	na	--
1,2,4-Trichlorobenzene	0	--	--	na	9.4E+02	--	--	na	9.4E+02	--	--	--	--	--	--	--	--	--	--	na	9.4E+02
1,1,2-Trichloroethane ^C	0	--	--	na	4.2E+02	--	--	na	4.2E+02	--	--	--	--	--	--	--	--	--	--	na	4.2E+02
Trichloroethylene ^C	0	--	--	na	8.1E+02	--	--	na	8.1E+02	--	--	--	--	--	--	--	--	--	--	na	8.1E+02
2,4,6-Trichlorophenol ^C	0	--	--	na	6.5E+01	--	--	na	6.5E+01	--	--	--	--	--	--	--	--	--	--	na	6.5E+01
2-(2,4,5-Trichlorophenoxy) propionic acid (Silvex)	0	--	--	na	--	--	--	na	--	--	--	--	--	--	--	--	--	--	--	na	--
Vinyl Chloride ^C	0	--	--	na	6.1E+01	--	--	na	6.1E+01	--	--	--	--	--	--	--	--	--	--	na	6.1E+01
Zinc	0	6.5E+01	6.6E+01	na	6.9E+04	6.5E+01	6.6E+01	na	6.9E+04	--	--	--	--	--	--	--	--	6.5E+01	6.6E+01	na	6.9E+04

Notes:

- All concentrations expressed as micrograms/liter (ug/l), unless noted otherwise
- Discharge flow is highest monthly average or Form 2C maximum for Industries and design flow for Municipals
- Metals measured as Dissolved, unless specified otherwise
- "C" indicates a carcinogenic parameter
- Regular WLAs are mass balances (minus background concentration) using the % of stream flow entered above under Mixing Information.
Antidegradation WLAs are based upon a complete mix.
- Antideg. Baseline = (0.25(WQC - background conc.) + background conc.) for acute and chronic
= (0.1(WQC - background conc.) + background conc.) for human health
- WLAs established at the following stream flows: 1Q10 for Acute, 30Q10 for Chronic Ammonia, 7Q10 for Other Chronic, 30Q5 for Non-carcinogens, Harmonic Mean for Carcinogens, and Annual Average for Dioxin. Mixing ratios may be substituted for stream flows where appropriate.

Metal	Target Value (SSTV)
Antimony	4.3E+03
Arsenic	9.0E+01
Barium	na
Cadmium	3.9E-01
Chromium III	2.5E+01
Chromium VI	6.4E+00
Copper	2.8E+00
Iron	na
Lead	3.4E+00
Manganese	na
Mercury	5.1E-02
Nickel	6.8E+00
Selenium	3.0E+00
Silver	4.2E-01
Zinc	2.6E+01

Note: do not use QL's lower than the minimum QL's provided in agency guidance

Analysis of the Notre Dame Academy effluent data for Ammonia

The statistics for Ammonia are:

Number of values	=	1
Quantification level	=	.2
Number < quantification	=	0
Expected value	=	29
Variance	=	302.76
C.V.	=	.6
97th percentile	=	70.56911
Statistics used	=	Reasonable potential assumptions - Type 2 data

The WLAs for Ammonia are:

Acute WLA	=	11.9
Chronic WLA	=	1.47
Human Health WLA	=	----

The limits are based on chronic toxicity and 1 samples/month.

Maximum daily limit	=	2.149985
Average monthly limit	=	2.149985

It is recommended that only the maximum daily limit be used.

11/20/2008 4:26:16 PM

Facility = Notre Dame Academy STP

Chemical = Ammonia

Chronic averaging period = 30

WLAa = 20

WLAc = 2.2

Q.L. = .2

samples/mo. = 1

samples/wk. = 1

Summary of Statistics:

observations = 1

Expected Value = 9

Variance = 29.16

C.V. = 0.6

97th percentile daily values = 21.9007

97th percentile 4 day average = 14.9741

97th percentile 30 day average = 10.8544

< Q.L. = 0

Model used = BPJ Assumptions, type 2 data

A limit is needed based on Chronic Toxicity

Maximum Daily Limit = 4.43887420551588

Average Weekly limit = 4.43887420551589

Average Monthly Limit = 4.43887420551589

The data are:

11/20/2008 4:23:48 PM

Facility = Notre Dame Academy STP

Chemical = Chlorine

Chronic averaging period = 4

WLAa = 0.019

WLAc = 0.011

Q.L. = .1

samples/mo. = 28

samples/wk. = 7

Summary of Statistics:

observations = 1

Expected Value = 20

Variance = 144

C.V. = 0.6

97th percentile daily values = 48.6683

97th percentile 4 day average = 33.2758

97th percentile 30 day average = 24.1210

< Q.L. = 0

Model used = BPJ Assumptions, type 2 data

A limit is needed based on Chronic Toxicity

Maximum Daily Limit = 1.60883226245855E-02

Average Weekly limit = 9.8252545713861E-03

Average Monthly Limit = 8.02152773888032E-03

The data are:

STREAM ASSIMILATION ANALYSIS

Stream: Goose Creek
 Discharge: Nature Name Academy

Date: 6-20-78
 Topo. Sheet:
 Critical Discharge: 009
 Gauging Station: Goose Creek
near Leesburg

Computation Number				
Drainage Area				
Stream temperature	30			
Saturation D.O.	7.6			
D.O. Discharge	5			
K ₁ (carbonaceous)215			
K _n (nitrogenous)	0			
K ₂ (reaeration)	1.2			
Flow, mgd (discharge)015			
BOD ₅ (discharge)	30			
NOD _u (discharge)	0			
Flow, mgd (stream)	0.5			
BOD ₅ (stream)	2			
NOD _u (stream)	0			
Length of segment (mi)	2			
Velocity of stream (fps)5			
D.O. (allowable)	6.6			
D.O. (stream)	(6.8)			
Δ D.O. from allowable	0.166			
(Red indicates violation)				
Flow (combined)	0.515			
BOD ₅ decay @ t	2.33			
NOD _u decay @ t	0			
time, days	2.24			
D.O. @ t ("A" indicates ...	6.77)			
Critical D.O.)				

Discharge
 results in no
 change in
 receiving
 stream.

Class III Recreability: small discharge, more than 20 miles upstream from public water supply.

Stream Data from Middleburg analysis used. Stream flow of 0.5 mgd is very conservative, as Goose Creek flow approximately 4 miles downstream is 1 mgd.

Standards for Nature Name Academy: 30 mg/l BOD₅ (+55)
 5.0 mg/l D.O.
 0.15 mgd Flow

Note: At the end of each segment, if critical D.O. has not been reached, the next stream segment should be analyzed. The parameter values determined @ time = t become the new "stream" data and new flows introduced to the stream (eg: tributaries, STP discharges, stretch flows) become the new "discharge" data. [K₁, K_n and K₂ must be adjusted as necessary]

mgd = (.646)cfs

Reviewer: Moore

Public Notice – Environmental Permit

PURPOSE OF NOTICE: To seek public comment on a draft permit from the Department of Environmental Quality that will allow the release of treated wastewater into a water body in Loudoun County, Virginia.

PUBLIC COMMENT PERIOD: January 15, 2009 to 5:00 p.m. on February 16, 2009

PERMIT NAME: Virginia Pollutant Discharge Elimination System Permit – Wastewater issued by DEQ, under the authority of the State Water Control Board

APPLICANT NAME, ADDRESS AND PERMIT NUMBER: Notre Dame Academy
35321 Notre Dame Lane, Middleburg, VA 20117
VA0027197

NAME AND ADDRESS OF FACILITY: Notre Dame Academy Sewage Treatment Plant
35321 Notre Dame Lane, Middleburg, VA 20117

PROJECT DESCRIPTION: Notre Dame Academy has applied for a reissuance of a permit for the private Notre Dame Academy STP. The applicant proposes to release treated sewage wastewaters from a small private school at a rate of 0.015 million gallons per day into a water body. Sludge from the treatment process will be transported to the Blue Plains WWTP (DC0021199) interceptor for final disposal. The facility proposes to release the treated sewage in the Goose Creek, UT, in Loudoun County in the Potomac River watershed. A watershed is the land area drained by a river and its incoming streams. The permit will limit the following pollutants to amounts that protect water quality: pH, BOD, TSS, DO, Chlorine, Ammonia and *E. coli*.

HOW TO COMMENT AND/OR REQUEST A PUBLIC HEARING: DEQ accepts comments and requests for public hearing by e-mail, fax or postal mail. All comments and requests must be in writing and be received by DEQ during the comment period. Submittals must include the names, mailing addresses and telephone numbers of the commenter/requester and of all persons represented by the commenter/requester. A request for public hearing must also include: 1) The reason why a public hearing is requested. 2) A brief, informal statement regarding the nature and extent of the interest of the requester or of those represented by the requestor, including how and to what extent such interest would be directly and adversely affected by the permit. 3) Specific references, where possible, to terms and conditions of the permit with suggested revisions. DEQ may hold a public hearing, including another comment period, if public response is significant and there are substantial, disputed issues relevant to the permit.

CONTACT FOR PUBLIC COMMENTS, DOCUMENT REQUESTS AND ADDITIONAL INFORMATION: The public may review the documents at the DEQ-Northern Regional Office by appointment.

Name: Douglas Frasier

Address: DEQ-Northern Regional Office, 13901 Crown Court, Woodbridge, VA 22193

Phone: (703) 583-3873 E-mail: ddfrasier@deq.virginia.gov Fax: (703) 583-3821

Revised 2/2003

**State "Transmittal Checklist" to Assist in Targeting
Municipal and Industrial Individual NPDES Draft Permits for Review**

Part I. State Draft Permit Submission Checklist

In accordance with the MOA established between the Commonwealth of Virginia and the United States Environmental Protection Agency, Region III, the Commonwealth submits the following draft National Pollutant Discharge Elimination System (NPDES) permit for Agency review and concurrence.

Facility Name:	Notre Dame Academy
NPDES Permit Number:	VA0027197
Permit Writer Name:	Douglas Frasier
Date:	1 December 2008

Major ☐

Minor ☒

Industrial ☐

Municipal ☒

I.A. Draft Permit Package Submittal Includes:

	Yes	No	N/A
1. Permit Application?	X		
2. Complete Draft Permit (for renewal or first time permit – entire permit, including boilerplate information)?	X		
3. Copy of Public Notice?	X		
4. Complete Fact Sheet?	X		
5. A Priority Pollutant Screening to determine parameters of concern?			X
6. A Reasonable Potential analysis showing calculated WQBELs?	X		
7. Dissolved Oxygen calculations?	X		
8. Whole Effluent Toxicity Test summary and analysis?			X
9. Permit Rating Sheet for new or modified industrial facilities?			X

I.B. Permit/Facility Characteristics

	Yes	No	N/A
1. Is this a new or currently unpermitted facility?		X	
2. Are all permissible outfalls (including combined sewer overflow points, non-process water and storm water) from the facility properly identified and authorized in the permit?	X		
3. Does the fact sheet or permit contain a description of the wastewater treatment process?	X		
4. Does the review of PCS/DMR data for at least the last 3 years indicate significant non-compliance with the existing permit?		X	
5. Has there been any change in streamflow characteristics since the last permit was developed?		X	
6. Does the permit allow the discharge of new or increased loadings of any pollutants?		X	
7. Does the fact sheet or permit provide a description of the receiving water body(s) to which the facility discharges, including information on low/critical flow conditions and designated/existing uses?	X		
8. Does the facility discharge to a 303(d) listed water?		X	
a. Has a TMDL been developed and approved by EPA for the impaired water?	X		
b. Does the record indicate that the TMDL development is on the State priority list and will most likely be developed within the life of the permit?			X
c. Does the facility discharge a pollutant of concern identified in the TMDL or 303(d) listed water?	X		
9. Have any limits been removed, or are any limits less stringent, than those in the current permit?		X	
10. Does the permit authorize discharges of storm water?		X	

I.B. Permit/Facility Characteristics – cont.	Yes	No	N/A
11. Has the facility substantially enlarged or altered its operation or substantially increased its flow or production?		X	
12. Are there any production-based, technology-based effluent limits in the permit?	X		
13. Do any water quality-based effluent limit calculations differ from the State's standard policies or procedures?		X	
14. Are any WQBELs based on an interpretation of narrative criteria?		X	
15. Does the permit incorporate any variances or other exceptions to the State's standards or regulations?		X	
16. Does the permit contain a compliance schedule for any limit or condition?		X	
17. Is there a potential impact to endangered/threatened species or their habitat by the facility's discharge(s)?		X	
18. Have impacts from the discharge(s) at downstream potable water supplies been evaluated?	X		
19. Is there any indication that there is significant public interest in the permit action proposed for this facility?		X	
20. Have previous permit, application, and fact sheet been examined?	X		

Part II. NPDES Draft Permit Checklist

Region III NPDES Permit Quality Checklist – for POTWs (To be completed and included in the record only for POTWs)

II.A. Permit Cover Page/Administration	Yes	No	N/A
1. Does the fact sheet or permit describe the physical location of the facility, including latitude and longitude (not necessarily on permit cover page)?	X		
2. Does the permit contain specific authorization-to-discharge information (from where to where, by whom)?	X		

II.B. Effluent Limits – General Elements	Yes	No	N/A
1. Does the fact sheet describe the basis of final limits in the permit (e.g., that a comparison of technology and water quality-based limits was performed, and the most stringent limit selected)?	X		
2. Does the fact sheet discuss whether “antibacksliding” provisions were met for any limits that are less stringent than those in the previous NPDES permit?			X

II.C. Technology-Based Effluent Limits (POTWs)	Yes	No	N/A
1. Does the permit contain numeric limits for <u>ALL</u> of the following: BOD (or alternative, e.g., CBOD, COD, TOC), TSS, and pH?	X		
2. Does the permit require at least 85% removal for BOD (or BOD alternative) and TSS (or 65% for equivalent to secondary) consistent with 40 CFR Part 133?	X		
a. If no, does the record indicate that application of WQBELs, or some other means, results in more stringent requirements than 85% removal or that an exception consistent with 40 CFR 133.103 has been approved?			X
3. Are technology-based permit limits expressed in the appropriate units of measure (e.g., concentration, mass, SU)?	X		
4. Are permit limits for BOD and TSS expressed in terms of both long term (e.g., average monthly) and short term (e.g., average weekly) limits?	X		
5. Are any concentration limitations in the permit less stringent than the secondary treatment requirements (30 mg/l BOD5 and TSS for a 30-day average and 45 mg/l BOD5 and TSS for a 7-day average)?		X	
a. If yes, does the record provide a justification (e.g., waste stabilization pond, trickling filter, etc.) for the alternate limitations?			X

II.D. Water Quality-Based Effluent Limits	Yes	No	N/A
1. Does the permit include appropriate limitations consistent with 40 CFR 122.44(d) covering State narrative and numeric criteria for water quality?	X		
2. Does the fact sheet indicate that any WQBELs were derived from a completed and EPA approved TMDL?	X		
3. Does the fact sheet provide effluent characteristics for each outfall?	X		
4. Does the fact sheet document that a “reasonable potential” evaluation was performed?	X		
a. If yes, does the fact sheet indicate that the “reasonable potential” evaluation was performed in accordance with the State’s approved procedures?	X		
b. Does the fact sheet describe the basis for allowing or disallowing in-stream dilution or a mixing zone?			X
c. Does the fact sheet present WLA calculation procedures for all pollutants that were found to have “reasonable potential”?	X		
d. Does the fact sheet indicate that the “reasonable potential” and WLA calculations accounted for contributions from upstream sources (i.e., do calculations include ambient/background concentrations)?			X
e. Does the permit contain numeric effluent limits for all pollutants for which “reasonable potential” was determined?	X		

II.D. Water Quality-Based Effluent Limits – cont.	Yes	No	N/A
5. Are all final WQBELs in the permit consistent with the justification and/or documentation provided in the fact sheet?	X		
6. For all final WQBELs, are BOTH long-term AND short-term effluent limits established?	X		
7. Are WQBELs expressed in the permit using appropriate units of measure (e.g., mass, concentration)?	X		
8. Does the record indicate that an “antidegradation” review was performed in accordance with the State’s approved antidegradation policy?	X		

II.E. Monitoring and Reporting Requirements	Yes	No	N/A
1. Does the permit require at least annual monitoring for all limited parameters and other monitoring as required by State and Federal regulations?	X		
a. If no, does the fact sheet indicate that the facility applied for and was granted a monitoring waiver, AND, does the permit specifically incorporate this waiver?			
2. Does the permit identify the physical location where monitoring is to be performed for each outfall?		X	
3. Does the permit require at least annual influent monitoring for BOD (or BOD alternative) and TSS to assess compliance with applicable percent removal requirements?		X	
4. Does the permit require testing for Whole Effluent Toxicity?			X


II.F. Special Conditions	Yes	No	N/A
1. Does the permit include appropriate biosolids use/disposal requirements?			X
2. Does the permit include appropriate storm water program requirements?			X

II.F. Special Conditions – cont.	Yes	No	N/A
3. If the permit contains compliance schedule(s), are they consistent with statutory and regulatory deadlines and requirements?			X
4. Are other special conditions (e.g., ambient sampling, mixing studies, TIE/TRE, BMPs, special studies) consistent with CWA and NPDES regulations?	X		
5. Does the permit allow/authorize discharge of sanitary sewage from points other than the POTW outfall(s) or CSO outfalls [i.e., Sanitary Sewer Overflows (SSOs) or treatment plant bypasses]?			X
6. Does the permit authorize discharges from Combined Sewer Overflows (CSOs)?			X
a. Does the permit require implementation of the “Nine Minimum Controls”?			X
b. Does the permit require development and implementation of a “Long Term Control Plan”?			X
c. Does the permit require monitoring and reporting for CSO events?			X
7. Does the permit include appropriate Pretreatment Program requirements?			X

II.G. Standard Conditions	Yes	No	N/A
1. Does the permit contain all 40 CFR 122.41 standard conditions or the State equivalent (or more stringent) conditions?	X		
List of Standard Conditions – 40 CFR 122.41			
Duty to comply	Property rights	Reporting Requirements	
Duty to reapply	Duty to provide information	Planned change	
Need to halt or reduce activity	Inspections and entry	Anticipated noncompliance	
not a defense	Monitoring and records	Transfers	
Duty to mitigate	Signatory requirement	Monitoring reports	
Proper O & M	Bypass	Compliance schedules	
Permit actions	Upset	24-Hour reporting	
		Other non-compliance	
2. Does the permit contain the additional standard condition (or the State equivalent or more stringent conditions) for POTWs regarding notification of new introduction of pollutants and new industrial users [40 CFR 122.42(b)]?	X		

Part III. Signature Page

Based on a review of the data and other information submitted by the permit applicant, and the draft permit and other administrative records generated by the Department/Division and/or made available to the Department/Division, the information provided on this checklist is accurate and complete, to the best of my knowledge.

Name	<u>Douglas Frasier</u>
Title	<u>Environmental Specialist II</u>
Signature	<u></u>
Date	<u>1 December 2008</u>